

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 926

Date: 11.12.20

It is certified that an inspection team headed by SRI RAJEEV KUMAR
Chauthary, Assistant Engineer, P.H. sub. division, Supaul (Name of Officers
with designation) from Public Health engineering (Name of
Department/Office) inspected the Rajanikant public school
veena Road, Supaul (Name & Address of
the School) on 11.12.2020 and found that the Rajanikant public
School Veena Road Supaul (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

Signature with Seal : [Signature] सहायक अभियंता
जनकपुर मंडल, सुपौल
Name Rajeev Kumar Chauthary
Designation Assistant Engineer

To
Rajanikant public school
veena Road Supaul
Supaul

(Name & Address of the Institution)

Public Health Engineering Department

Date of sampling- 11/12/2020

Date of Testing:- 11/12/2020

District Name: Supaul

Sample collected by :- School Staff

Sl. No.	Block	Location of Source	Type of sample (Raw/ Treated)water	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	SO ₄	F	Total Coll	Remarks
1	Supaul	Rainikant Public School , Supaul (campus)	Treated Water	7.10	0.4	105	68	44	10	3	16	8	0.34	5	0.2	NIL	safe
Desirable Limit.				6.5	5	-	500	200	75	30	250	200	0.3	200	1.0	-	
Permissible Limit* in absence of alternate source				8.5	10	-	2000	600	200	100	1000	600	1.0	400	1.5	**	

Stiv
11/12/2020
Lab. Assistant / Chemist

Chaitanya Kumar
11/12/2020
Assistant Engineer P.H.
Sub Division, Supaul